

200/EM/ 278 /E2

K-150117

Office of AGE E/M Chilka

07 Dec 2017

Kendriya Vidyalaya
INS Chilka


WATER TEST REPORT


1. Ref your office letter No 150117/1/KVC/1161/2017-18 dt 24 Nov 2017.
2. The subject report asked vide your above mentioned letter is forwarded herewith as per Appx "A" for your further necessary action please.

Copy to :-

GE Chilka

- for info please.


(R S Nayaka)
AE (E/M)
AGE (E/M) Chilka


9.12.17



STATE WATER TESTING LABORATORY, RWS&S (O), KHANDAGIRI, BHUBANESWAR.

e-mail : rwsscentrallabodisha@gmail.com, Ph. No: 0674 – 2386280

Analytical Report

Test Report No. SWTL-TR/212/2017/S-1-3	Date of Issue :- 30.11.2017
--	-----------------------------

Name of Customer :- Military Engineer Services // Garrison Engineer, Chilika

Sample Registration Details	
Type of Source :	Raw Water & Treated Water
Date of Sample Collection :	Not specified
Sample Receive Date :	29.11.2017 (11.30 AM) Vide letter No 19/dated 28.11.2017
Sample Registration Date :	29.11.2017
Quantity of Sample Received :	01 ltr. (each Sample)
Sample collected by	Not specified.
Location of the Sample :	As per letter under reference(above)
Sampling Protocol :	Samples are not collected by this laboratory.
Period of Analysis :	Dt. 29.11.2017 & 30.11.2017



Cert. No. TC -6094
(In lieu of T-4063)
NABL Accredited Lab.

Sl.	Test Parameters	Units	Results	Requirements IS 10500 : 2012		Test Method
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	Total Coliforms* Bacteria	NPN/ 100ml	1- <u>>200.5</u> 2- <1.0 3- <u>>200.5</u>	Shall not be detectable in any 100ml Sample		Coliort-18/1 IDXX-Quanty Tray, [Enzyme Substrate Test] APHA22 nd Ed.9223 B]
2	E.coli*	NPN/ 100ml	1- <u>>144.5</u> 2- <1.0 3- <1.0			

Note :- The samples were tested with dilution.

Information on Test Report :

Results relates only to samples received in the Laboratory.

The test report shall not be reproduced except in full without written approval of SWTL.

#APHA – American Public Health Association

*The parameters are not accredited by NABL.

Checked & Compared by

(Signature)
30/11/17
(A.K.Baral)
Technical Manager

(Signature)
30/11/2017
(N.K.Panda)

Analyst (Chemist) & Quality Manager,
State Water Testing Laboratory
Authorised Signatory

केन्द्रीय विद्यालय / KENDRIYA VIDYALAYA
नौ पो चिल्का / INS CHILKA ओडिशा / ODISHA